

40 C.F.R. § 63.11212

What stack tests and procedures must I use for the performance tests?

- (a) You must conduct all performance tests according to § 63.7(c), (d), (f), and (h). You must also develop a site-specific test plan according to the requirements in § 63.7(c).
- (b) You must conduct each stack test according to the requirements in Table 4 to this subpart. Boilers that use a CEMS for carbon monoxide (CO) are exempt from the initial CO performance testing in Table 4 to this subpart and the oxygen concentration operating limit requirement specified in Table 3 to this subpart.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)