
40 C.F.R. § 63.1184

What do I need to know about the design specifications, installation, and operation of a bag leak detection system?

A bag leak detection system must meet the following requirements:

- (a) The bag leak detection system must be certified by the manufacturer to be capable of detecting PM emissions at concentrations of 10 milligrams per actual cubic meter (0.0044 grains per actual cubic foot) or less.
- (b) The sensor on the bag leak detection system must provide output of relative PM emissions.
- (c) The bag leak detection system must have an alarm that will sound automatically when it detects an increase in relative PM emissions greater than a preset level.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)