

40 C.F.R. § 63.3968

What are the requirements for continuous parameter monitoring system installation, operation, and maintenance?

- (a) *General.* You must install, operate, and maintain each CPMS specified in paragraphs (c), (e), (f), and (g) of this section according to paragraphs (a)(1) through (6) of this section. You must install, operate, and maintain each CPMS specified in paragraphs (b) and (d) of this section according to paragraphs (a)(3) through (5) of this section.
- (1) The CPMS must complete a minimum of one cycle of operation for each successive 15-minute period. You must have a minimum of four equally spaced successive cycles of CPMS operation in 1 hour.
- (2) You must determine the average of all recorded readings for each successive 3-hour period of the emission capture system and add-on control device operation.
- (3) You must record the results of each inspection, calibration, and validation check of the CPMS.
- (4) Before January 5, 2021, you must maintain the CPMS at all times and have available necessary parts for routine repairs of the monitoring equipment. On and after January 5, 2021, you must maintain the CPMS at all times in accordance with § 63.3900(b) and keep necessary parts readily available for routine repairs of the monitoring equipment.
- (5) Before January 5, 2021, you must operate the CPMS and collect emission capture system and add-on control device parameter data at all times that a controlled coating operation is operating, except during monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, if applicable, calibration checks and required zero and span adjustments). On and after January 5, 2021, you must operate the CPMS and collect emission capture system and add-on control device parameter data at all times in accordance with § 63.3900(b).
- (6) You must not use emission capture system or add-on control device parameter data recorded during monitoring malfunctions, associated repairs, out-of-control periods, or required quality assurance or control activities when calculating data averages. You must use all the data collected during all other periods in calculating the data averages for determining compliance with the emission capture system and add-on control device operating limits.
- (7) A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the CPMS to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. Before January 5, 2021, any period for which the monitoring system is out-of-control and data are not available for required calculations is a deviation from the monitoring requirements. On and after January 5, 2021, except for periods of required quality assurance or control activities, any period for which the CPMS fails to operate and record data continuously as required by paragraph (a)(5) of this section, or generates data that cannot be included in calculating averages as specified in (a)(6) of this section constitutes a deviation

from the monitoring requirements.
This document is only available to subscribers. Please log in or purchase access.
<u>Purchase Login</u>
copyright © 2024 by Society of Corporate Compliance and Ethics (SCCE) & Health Care Compliance Association (HCCA). No claim to original US
envernment works. All rights recoved. Haggs is governed under this website's Torms of Hea