
40 C.F.R. § 63.404

Compliance demonstrations.

No routine monitoring, sampling, or analysis is required. In accordance with section 114 of the Act, the Administrator or delegated authority can require cooling water sample analysis of an IPCT if there is information to indicate that the IPCT is not in compliance with the requirements of § 63.402 of this subpart. The owner or operator of an IPCT may demonstrate compliance through recordkeeping in accordance with paragraph (c) of this section in lieu of a water sample analysis. If cooling water sample analysis is required:

- (a) The water sample analysis shall be conducted in accordance with Method 7196, Chromium, Hexavalent (Colorimetric), contained in the Third Edition of “Test Methods for Evaluating Solid Waste, Physical/Chemical Methods,” EPA Publication SW-846, (November 1986) and its Revision I, (December 1987), which are available for the cost of \$110.00 from the Government Printing Office, Superintendent of Documents, Washington, DC 20402, (202) 783-3238 (document number 955-001-00000-1; or Method 3500-Cr D, Colorimetric Method, contained in the 18th Edition of “Standard Methods for the Examination of Water and Wastewater” (1992), which is available from the American Public Health Association, 1015 15th Street, NW., Washington, DC 20005. These methods were approved for incorporation by reference by the Director of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. Copies may be inspected as a part of Docket A-91-65, located at the Air and Radiation Docket and Information Center, room M1500, EPA Central Docket Section, 401 M St., SW., Washington, DC. Copies may be inspected at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to:
http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)