
40 C.F.R. § 63.660

Storage vessel provisions.

On and after the applicable compliance date for a Group 1 storage vessel located at a new or existing source as specified in § 63.640(h), the owner or operator of a Group 1 storage vessel storing liquid with a maximum true vapor pressure less than 76.6 kilopascals (11.1 pounds per square inch) that is part of a new or existing source shall comply with either the requirements in subpart WW or SS of this part according to the requirements in paragraphs (a) through (i) of this section and the owner or operator of a Group 1 storage vessel storing liquid with a maximum true vapor pressure greater than or equal to 76.6 kilopascals (11.1 pounds per square inch) that is part of a new or existing source shall comply with the requirements in subpart SS of this part according to the requirements in paragraphs (a) through (i) of this section.

(a) As used in this section, all terms not defined in § 63.641 shall have the meaning given them in subpart A, WW, or SS of this part. The definitions of “Group 1 storage vessel” (paragraph (2)) and “Storage vessel” in § 63.641 shall apply in lieu of the definition of “Storage vessel” in § 63.1061.

(1) An owner or operator may use good engineering judgment or test results to determine the stored liquid weight percent total organic HAP for purposes of group determination. Data, assumptions, and procedures used in the determination shall be documented.

(2) When an owner or operator and the Administrator do not agree on whether the annual average weight percent organic HAP in the stored liquid is above or below 4 percent for a storage vessel at an existing source or above or below 2 percent for a storage vessel at a new source, an appropriate method (based on the type of liquid stored) as published by EPA or a consensus-based standards organization shall be used. Consensus-based standards organizations include, but are not limited to, the following: ASTM International (100 Barr Harbor Drive, P.O. Box CB700, West Conshohocken, Pennsylvania 19428-B2959, (800) 262-1373, <http://www.astm.org>), the American National Standards Institute (ANSI, 1819 L Street NW., 6th Floor, Washington, DC 20036, (202) 293-8020, <http://www.ansi.org>), the American Gas Association (AGA, 400 North Capitol Street NW., 4th Floor, Washington, DC 20001, (202) 824-7000, <http://www.aga.org>), the American Society of Mechanical Engineers (ASME, Three Park Avenue, New York, NY 10016-5990, (800) 843-2763, <http://www.asme.org>), the American Petroleum Institute (API, 1220 L Street NW., Washington, DC 20005-4070, (202) 682-8000, <http://www.api.org>), and the North American Energy Standards Board (NAESB, 801 Travis Street, Suite 1675, Houston, TX 77002, (713) 356-0060, <http://www.naesb.org>).

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)