

29 C.F.R. § 1915.181

Electrical circuits and distribution boards.

- (a) The provisions of this section shall apply to ship repairing and shipbuilding and shall not apply to shipbreaking.
- (b) Before an employee is permitted to work on an electrical circuit, except when the circuit must remain energized for testing and adjusting, the circuit shall be deenergized and checked at the point at which the work is to be done to insure that it is actually deenergized. When testing or adjusting an energized circuit a rubber mat, duck board, or other suitable insulation shall be used underfoot where an insulated deck does not exist.

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)