

---

## 29 C.F.R. § 1926.758

---

### Systems-engineered metal buildings.

---

- (a) All of the requirements of this subpart apply to the erection of systems-engineered metal buildings except §§ 1926.755 (column anchorage) and 1926.757 (open web steel joists).
- (b) Each structural column shall be anchored by a minimum of four anchor rods (anchor bolts).
- (c) Rigid frames shall have 50 percent of their bolts or the number of bolts specified by the manufacturer (whichever is greater) installed and tightened on both sides of the web adjacent to each flange before the hoisting equipment is released.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)