

42 C.F.R. § 483.90

Physical environment.

The facility must be designed, constructed, equipped, and maintained to protect the health and safety of residents, personnel and the public.

(a) *Life safety from fire.* (1) Except as otherwise provided in this section—

(i) The LTC facility must meet the applicable provisions and must proceed in accordance with the Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4.)

(ii) Notwithstanding paragraph (a)(1)(i) of this section, corridor doors and doors to rooms containing flammable or combustible materials must be provided with positive latching hardware. Roller latches are prohibited on such doors.

(iii) If a facility is Medicare- or Medicaid-certified before July 5, 2016 and the facility has previously used the Fire Safety Evaluation System for compliance, the facility may use the scoring values in the following Mandatory Values Chart:

Table 1 to paragraph (a)(1)(iii) -- Mandatory Values—Nursing Homes

Zone Location	Containment (Sa)		Extinguishment (Sb)		People Movement (Sc)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)*	4	8(5)*	1
2 nd or 3 rd story	15	9	17(14)*	6	10(7)*	3
4 th story or higher	18	9	19(16)*	6	11(8)*	3

*Use () in zones that do not contain patient sleeping rooms.

(2) In consideration of a recommendation by the State survey agency or Accrediting Organization or at the discretion of the Secretary, may waive, for periods deemed appropriate, specific provisions of the Life Safety Code, which would result in unreasonable hardship upon a long-term care facility, but only if the waiver will not adversely affect the health and safety of the patients.

(3) The provisions of the Life safety Code do not apply in a State where CMS finds, in accordance with applicable provisions of sections 1819(d)(2)(B)(ii) and 1919(d)(2)(B)(ii) of the Act, that a fire and safety code imposed by State law adequately protects patients, residents and personnel in long term care facilities.

(4) A long-term care facility may install alcohol-based hand rub dispensers in its facility if the dispensers are installed in a manner that adequately protects against inappropriate access.

(5) A long term care facility must:

(i) Install, at least, battery-operated single station smoke alarms in accordance with the manufacturer's recommendations in resident sleeping rooms and common areas.

(ii) Have a program for inspection, testing, maintenance, and battery replacement that conforms to the

manufacturer's recommendations and that verifies correct operation of the smoke alarms.

(iii) Exception:

(A) The facility has system-based smoke detectors in patient rooms and common areas that are installed, tested, and maintained in accordance with NFPA 72, *National Fire Alarm Code*, for system-based smoke detectors; or

(B) The facility is fully sprinklered in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

(6) A long term care facility must:

(i) Install an approved, supervised automatic sprinkler system in accordance with the 1999 edition of NFPA 13, *Standard for the Installation of Sprinkler Systems*, as incorporated by reference, throughout the building by August 13, 2013. The Director of the Office of the Federal Register has approved the NFPA 13 1999 edition of the *Standard for the Installation of Sprinkler Systems*, issued July 22, 1999 for incorporation by reference in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. A copy of the Code is available for inspection at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. Copies may be obtained from the National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02269.

This document is only available to subscribers. Please log in or purchase access.

[Purchase Login](#)