

---

# 40 C.F.R. § 84.58

---

## Labeling.

---

(a) Effective upon the dates listed for each subsector in § 84.54(a) and (c), any product, specified component, or system manufactured, imported, or installed within the refrigeration, air-conditioning, and heat pump sector using any regulated substance, or blend containing any regulated substance, regardless of global warming potential must have a permanent label compliant with paragraph (d) of this section stating:

- (1) The chemical name(s) or American Society of Heating, Refrigerating and Air-Conditioning Engineers designation of the regulated substance(s) or blend containing a regulated substance;
- (2) The full date, or at minimum the four-digit year, of manufacture. For field-charged system installations, this shall be the date of first charge and the label shall be completed at first charge. For MVACs listed in § 84.54(a)(13)(i) and (ii), the model year may be used instead of the date of manufacture.
- (3) An indication of the full refrigerant charge capacity, either as the specific charge size of the system, or the charge size as it relates to the threshold for the relevant subsector. This means an indication that the charge is either two hundred pounds or more, or less than two hundred pounds, in the following subsectors:

This document is only available to subscribers. Please [log in](#) or [purchase access](#).

[Purchase Login](#)